



| 反射率(%) |               |    |     |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
|--------|---------------|----|-----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|
| 天井     | 80            |    |     |    | 70 |    |    |    | 50 |    |    |    | 30 |    |    |    | 20 | 0  |    |    |
| 壁      | 70            | 50 | 30  | 10 | 70 | 50 | 30 | 10 | 70 | 50 | 30 | 10 | 70 | 50 | 30 | 10 | 70 | 50 | 30 | 10 |
| 床      | 30            | 10 | 30  | 10 | 30 | 10 | 30 | 10 | 30 | 10 | 30 | 10 | 30 | 10 | 30 | 10 | 30 | 10 | 30 | 10 |
| 室指数    | 作業面照明率(×0.01) |    |     |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| 0.60   | 49            | 45 | 36  | 34 | 28 | 28 | 23 | 23 | 47 | 43 | 35 | 33 | 28 | 27 | 23 | 22 | 43 | 40 | 33 | 32 |
| 0.80   | 59            | 54 | 46  | 44 | 38 | 37 | 32 | 32 | 56 | 52 | 45 | 42 | 37 | 36 | 32 | 31 | 52 | 48 | 42 | 40 |
| 1.00   | 66            | 59 | 54  | 50 | 46 | 43 | 40 | 38 | 63 | 57 | 52 | 49 | 44 | 42 | 39 | 38 | 58 | 53 | 49 | 46 |
| 1.25   | 73            | 65 | 61  | 56 | 53 | 50 | 47 | 45 | 69 | 62 | 59 | 55 | 52 | 49 | 46 | 44 | 63 | 58 | 55 | 52 |
| 1.50   | 78            | 68 | 67  | 61 | 59 | 55 | 53 | 50 | 74 | 66 | 64 | 59 | 57 | 53 | 51 | 49 | 67 | 62 | 60 | 56 |
| 2.00   | 84            | 73 | 75  | 67 | 67 | 62 | 62 | 57 | 80 | 71 | 72 | 65 | 65 | 60 | 60 | 56 | 73 | 67 | 66 | 62 |
| 2.50   | 88            | 76 | 80  | 71 | 73 | 66 | 68 | 62 | 84 | 74 | 77 | 69 | 71 | 65 | 66 | 61 | 76 | 70 | 71 | 65 |
| 3.00   | 91            | 78 | 84  | 74 | 78 | 69 | 73 | 66 | 87 | 76 | 80 | 72 | 75 | 68 | 70 | 64 | 79 | 72 | 74 | 68 |
| 4.00   | 95            | 81 | 89  | 77 | 84 | 74 | 80 | 71 | 91 | 79 | 85 | 75 | 81 | 72 | 77 | 69 | 82 | 74 | 78 | 71 |
| 5.00   | 98            | 83 | 93  | 80 | 88 | 77 | 84 | 74 | 93 | 80 | 88 | 78 | 84 | 75 | 81 | 72 | 84 | 76 | 81 | 74 |
| 7.00   | 101           | 85 | 97  | 82 | 93 | 80 | 90 | 78 | 96 | 82 | 92 | 80 | 89 | 78 | 86 | 76 | 87 | 78 | 84 | 76 |
| 10.00  | 103           | 86 | 100 | 84 | 97 | 83 | 95 | 81 | 98 | 84 | 95 | 82 | 93 | 81 | 91 | 79 | 88 | 80 | 87 | 78 |

JIS C 8030:2014

三菱電機照明株式会社