



作業面照明率 (× 0 . 0 1)															
反射率 (%)			室指数												
天井	壁	床	0.4	0.6	0.8	1.0	1.25	1.5	2.0	2.5	3.0	4.0	5.0	7.0	10.0
80	70	30	37	50	59	66	73	78	86	91	94	99	102	106	109
		10	35	46	53	59	65	69	74	78	81	84	86	89	91
	50	30	24	36	44	52	59	65	74	80	84	91	95	100	105
		10	23	34	42	48	54	59	66	71	74	78	81	85	88
	30	30	17	27	35	42	49	55	64	71	76	83	89	95	100
70		10	17	26	33	40	46	51	59	64	68	73	77	82	85
	10	10	13	21	27	33	40	45	52	58	63	69	73	78	83
	70	30	35	47	55	62	68	73	80	84	88	92	95	98	101
		10	33	43	50	56	61	65	70	74	77	80	82	85	87
	50	30	23	34	42	49	56	61	69	75	79	85	89	94	98
50		10	22	32	39	46	52	56	63	67	70	75	78	81	84
	30	30	17	26	33	40	47	52	61	67	72	78	83	89	94
		10	16	25	32	38	44	49	56	61	65	70	74	78	82
	10	10	12	20	26	32	38	43	50	56	60	66	70	75	79
	50	30	21	30	37	43	49	54	61	66	69	74	77	82	85
30		10	20	29	35	41	47	50	56	61	64	68	71	74	77
	30	30	15	24	30	36	42	47	54	60	64	69	73	78	82
		10	15	23	29	34	40	44	51	56	59	64	67	71	75
	10	10	11	19	24	29	35	39	46	51	55	60	64	69	73
	30	30	13	21	27	32	38	42	48	53	56	61	64	68	72
0		10	13	21	26	31	37	40	46	51	54	58	61	65	68
	10	10	10	17	22	27	32	36	42	47	50	55	59	63	66
0	0	0	7	13	17	22	26	30	35	39	42	47	50	53	57