

騒音分析成績書

機種：MPL-RP50, 56JA3

グラフ 記号		バンド Hz								オーバーオール値 dB[A特性]
		63	125	250	500	1000	2000	4000	8000	
○	強	33.0	34.3	36.3	35.8	31.8	28.2	20.2	14.0	37
●	中1	31.8	33.6	34.9	34.4	30.2	26.7	18.3	12.9	35.5
△	中2	30.6	32.9	33.3	33.0	28.5	25.0	16.4	11.6	34
▲	弱	29.0	31.7	31.4	31.1	26.4	23.0	14.0	10.0	32

