

騒音分析成績書

機種：MPLZ-RP160BA3

ゲラフ 記号	風量	バンド Hz								オーバーオール値 dB[A特性]
		63	125	250	500	1000	2000	4000	8000	
○—○	強	46.1	48.5	47.9	41.7	38.0	30.8	24.5	14.2	44
●—●	中	42.7	46.5	46.2	39.7	35.8	28.1	21.2	11.2	42
□—□	弱	39.8	44.4	43.5	36.7	32.2	24.1	16.1	9.0	39
■—■	静粛	37.0	42.7	40.6	33.5	29.1	20.1	12.9	8.5	36

