

騒音分析成績書

機種：MPM-RP50EA3, RP56EA3

| ゲラフ 記号 | 風量 | バンド Hz | | | | | | | | オーバーオール値 dB[A特性] |
|-----------|-------|--------|------|------|------|------|------|------|------|---------------------|
| | | 63 | 125 | 250 | 500 | 1000 | 2000 | 4000 | 8000 | |
| ○ | 強60Hz | 34.0 | 43.5 | 46.0 | 43.5 | 42.0 | 37.5 | 30.5 | 23.0 | 46 |
| ● | 強50Hz | 32.5 | 41.0 | 43.5 | 41.0 | 38.5 | 34.0 | 26.0 | 19.0 | 43 |
| □ | 弱60Hz | 30.5 | 38.0 | 41.0 | 38.5 | 35.0 | 30.5 | 21.0 | 14.0 | 40 |
| ■ | 弱60Hz | 29.0 | 36.0 | 38.5 | 36.5 | 33.0 | 28.0 | 19.5 | 12.0 | 38 |

