

騒音分析成績書

機種：MPUZ-P140HA5, MPU-P140HA5

| グラフ記号 | | バンド Hz | | | | | | | | オーバーオール値 |
|-------|----|--------|------|------|------|------|------|------|------|----------|
| | | 63 | 125 | 250 | 500 | 1000 | 2000 | 4000 | 8000 | dB[A特性] |
| ○ | 冷房 | 51.5 | 53.3 | 51.2 | 46.7 | 44.6 | 41.8 | 36.6 | 30.7 | 50.0 |
| ● | 暖房 | 53.2 | 55.5 | 52.6 | 49.0 | 46.8 | 43.5 | 38.5 | 32.0 | 52.0 |

