

騒音分析成績書

機種：MPUZ-RP160HA8, MPU-RP160HA8

グラフ 記号		バンド Hz								オーバーオール値
		63	125	250	500	1000	2000	4000	8000	dB[A特性]
○	冷房	51.3	56.3	54.2	49.0	46.5	42.2	37.6	30.9	52
●	暖房	54.3	60.9	55.5	51.8	49.9	45.6	41.3	35.1	55

