

騒音分析成績書

機種：PCZ-KP140KM7

グラフ 記号	風量	バンド Hz								オーバーオール値 dB [A特性]
		63	125	250	500	1000	2000	4000	8000	
○—○	強	34.3	38.0	42.5	40.7	40.0	36.4	29.8	20.6	44
●—●	中1	33.3	37.1	41.1	39.0	37.8	34.3	26.5	18.0	42
□—□	中2	31.2	35.1	38.7	36.3	34.7	31.1	22.3	14.4	39
■—■	静粛	29.0	32.9	36.1	33.5	31.5	27.9	18.1	10.9	36

