

騒音分析成績書

機種：PL-ERP80HA

| グラフ 記号 | 風量 | バンド [*] Hz | | | | | | | | オーバーオール値 dB[A特性] |
|-----------|----|---------------------|------|------|------|------|------|------|------|---------------------|
| | | 63 | 125 | 250 | 500 | 1000 | 2000 | 4000 | 8000 | |
| ○ ○ | 強 | 38.7 | 38.2 | 41.3 | 32.7 | 29.5 | 21.4 | 16.1 | 14.8 | 36.0 |
| ● ● | 中 | 37.7 | 37.2 | 40.4 | 31.7 | 28.6 | 20.4 | 14.6 | 13.8 | 35.0 |
| □ □ | 弱 | 34.8 | 34.1 | 38.0 | 27.7 | 25.2 | 15.7 | 13.5 | 12.5 | 32.0 |
| ■ ■ | 静粛 | 32.9 | 32.6 | 35.0 | 24.6 | 21.6 | 13.2 | 12.3 | 11.0 | 29.0 |

