

# 騒音分析成績書

機種 : PLFY-P45GMG9

グラフ 記号	風量	バンド Hz								オーバーオール値 dB[A特性]
		63	125	250	500	1000	2000	4000	8000	
○—○	強	44.0	47.2	42.0	36.3	33.0	24.7	16.8	10.7	39.0
●—●	中1	44.3	43.8	39.4	33.5	29.8	19.5	13.2	11.1	36.0
□—□	中2	43.8	41.5	38.5	33.0	28.7	18.2	12.7	11.2	35.0
■—■	弱	43.7	40.2	37.7	32.1	27.4	16.9	12.0	11.1	34.0

