

騒音分析成績書

機種：PLFY-EP140EMG8

グラフ 記号	風量	バンド Hz								オーバーオール値
		63	125	250	500	1000	2000	4000	8000	dB[A特性]
○—○	強	57.0	47.8	47.5	43.6	41.3	34.0	30.6	21.8	46.0
●—●	中	51.6	44.3	44.4	41.0	38.5	30.7	27.0	17.9	43.0
□—□	弱	44.5	40.8	41.6	37.1	34.2	25.1	20.9	14.4	39.0
■—■	静粛	40.9	37.7	38.0	33.4	29.6	20.0	15.9	12.8	35.0

