

騒音分析成績書

機種 : PLFY-EP160HMG9

| ゲラフ 記号 | 風量 | バンド Hz | | | | | | | | オーバーオール値 dB[A特性] |
|-----------|----|--------|------|------|------|------|------|------|------|---------------------|
| | | 63 | 125 | 250 | 500 | 1000 | 2000 | 4000 | 8000 | |
| ○—○ | 強 | 39.8 | 47.7 | 47.4 | 42.0 | 42.3 | 35.7 | 30.4 | 20.7 | 46.0 |
| ●—● | 中1 | 37.7 | 44.4 | 44.8 | 39.6 | 39.1 | 32.5 | 26.0 | 16.4 | 43.0 |
| □—□ | 中2 | 35.3 | 40.2 | 40.9 | 36.0 | 35.0 | 28.1 | 20.5 | 12.0 | 39.0 |
| ■—■ | 弱 | 34.4 | 37.3 | 38.6 | 33.5 | 31.7 | 23.8 | 15.8 | 10.3 | 36.0 |

