

# 騒音分析成績書

機種：PLFY-P36・45JMG6

グラフ 記号		バンド Hz								オーバーオール値
		63	125	250	500	1000	2000	4000	8000	dB[A特性]
○	強	31.5	32.3	34.0	33.8	30.0	26.2	18.0	11.0	35
●	中1	30.9	31.9	33.1	32.8	28.8	25.1	17.0	11.0	34
△	中2	29.7	31.0	31.8	31.4	27.1	23.5	15.4	10.4	32.5
▲	弱	28.7	30.2	30.5	30.0	25.5	22.0	14.0	10.0	31

