

# 騒音分析成績書

機種 : PL-RP40/45GA2

ゲラフ 記号	風量	バンド Hz								オーバ-オール値 dB[A特性]
		63	125	250	500	1000	2000	4000	8000	
○—○	強	43.2	44.2	41.2	36.1	31.8	24.0	15.8	10.8	38.0
●—●	中	43.6	43.5	39.9	34.1	28.5	19.3	13.0	11.3	36.0
□—□	弱	43.6	40.6	37.9	32.3	26.6	17.0	11.7	10.4	34.0
■—■	静粛	43.7	38.9	37.1	31.3	25.3	15.6	11.3	10.5	33.0

