

騒音分析成績書

機種：PL-RP50JA12, PL-RP56JA12

ゲラフ 記号		バンド Hz								オーバーオール値
		63	125	250	500	1000	2000	4000	8000	dB[A特性]
○	強	33.0	34.3	36.3	35.8	31.8	28.2	20.2	14.0	37
●	中	31.8	33.6	34.9	34.4	30.2	26.7	18.3	12.9	35.5
△	弱	30.6	32.9	33.3	33.0	28.5	25.0	16.4	11.6	34
▲	静	29.0	31.7	31.4	31.1	26.4	23.0	14.0	10.0	32

