

騒音分析成績書

機種：PM-HRP80FA19

| グラフ記号 | 風量 | バンド Hz | | | | | | | | オーバーオール値 dB[A特性] |
|-------|----|--------|------|------|------|------|------|------|------|---------------------|
| | | 63 | 125 | 250 | 500 | 1000 | 2000 | 4000 | 8000 | |
| ○—○ | 強 | 42.6 | 42.2 | 42.2 | 38.5 | 37.6 | 34.3 | 26.6 | 16.1 | 42.0 |
| ●—● | 中 | 40.7 | 38.8 | 38.9 | 35.0 | 33.4 | 29.6 | 21.5 | 12.7 | 38.0 |
| □—□ | 弱 | 39.5 | 36.3 | 36.5 | 32.3 | 30.2 | 25.9 | 17.4 | 10.2 | 35.0 |
| ■—■ | 静粛 | 38.1 | 33.7 | 33.9 | 29.5 | 27.0 | 22.3 | 13.4 | 7.6 | 32.0 |

