

騒音分析成績書

機種：PMFY-P71・80EM-E1

| グラフ記号 | | バンド [°] Hz | | | | | | | | オーバーオール値 dB[A特性] |
|-------|---------|---------------------|------|------|------|------|------|------|------|---------------------|
| | | 63 | 125 | 250 | 500 | 1000 | 2000 | 4000 | 8000 | |
| ○ | 強(50Hz) | 30.0 | 40.5 | 42.5 | 40.0 | 37.5 | 32.5 | 25.5 | 19.0 | 42 |
| ● | 強(60Hz) | 31.0 | 41.0 | 44.0 | 42.0 | 39.0 | 35.5 | 29.0 | 22.0 | 44 |
| △ | 弱(50Hz) | 27.5 | 37.5 | 38.0 | 35.5 | 32.0 | 26.5 | 20.0 | 13.5 | 37 |
| ▲ | 弱(60Hz) | 26.5 | 36.0 | 38.5 | 35.5 | 32.0 | 26.5 | 19.0 | 13.0 | 37 |

