

# 騒音分析成績書

機種：PMFY-P45BMG4

グラフ 記号		バンド Hz								オーバーオール値 dB[A特性]
		63	125	250	500	1000	2000	4000	8000	
○	強	37.2	29.8	36.5	34.3	36.7	29.8	20.0	8.7	39
●	中1	35.2	27.8	34.5	32.3	34.7	27.8	18.0	6.7	37
△	中2	33.2	25.8	32.5	30.3	32.7	25.8	16.0	4.7	35
▲	弱	31.2	23.8	30.5	28.3	30.7	23.8	14.0	2.7	33

