

# 騒音分析成績書

機種：PM-RP40FA15, PM-RP45FA15, PM-RP50FA15

グラフ 記号	風量	バンド <sup>°</sup> Hz								オーバーオール値 dB[A特性]
		63	125	250	500	1000	2000	4000	8000	
○—○	強	40.6	38.1	38.1	34.7	34.0	29.1	23.4	13.5	38.0
●—●	中	40.2	35.9	36.2	31.8	30.7	25.8	19.6	11.3	35.0
□—□	弱	39.4	33.7	34.1	28.7	27.3	22.4	15.7	9.0	32.0
■—■	静粛	38.4	31.2	31.9	25.6	23.9	19.0	11.9	6.5	29.0

