

# 騒音分析成績書

機種：PM-RP63FA15

グラフ 記号	風量	バンド Hz								オーバーオール値 dB[A特性]
		63	125	250	500	1000	2000	4000	8000	
○—○	強	38.6	42.3	39.8	36.2	34.4	29.8	21.9	14.3	39.0
●—●	中	38.3	41.0	38.2	34.4	32.3	27.2	19.5	12.9	37.0
□—□	弱	37.9	39.6	36.6	32.4	30.1	24.7	17.2	11.5	35.0
■—■	静粛	37.1	37.4	34.1	29.5	26.7	20.8	13.6	9.2	32.0

