

騒音分析成績書

機種：PUZ-ERP280KA11

グラフ 記号		バンド Hz								オーバーオール値
		63	125	250	500	1000	2000	4000	8000	dB[A特性]
○	冷房	62.8	60.5	57.4	55.3	55.3	50.7	43.9	38.3	59
●	暖房	66.6	61.7	60.5	58.7	58.4	52.9	47.2	41.2	62

