

騒音分析成績書

機種：PUZ-ERP280KA4

グラフ 記号		バンド Hz								オーバーオール値
		63	125	250	500	1000	2000	4000	8000	dB [A特性]
○	冷房	63.8	61.4	58.4	55.4	54.8	50.7	45.3	37.1	59
●	暖房	66.0	61.5	58.5	56.6	56.4	50.8	45.0	38.2	60

