

騒音分析成績書

機種：PUZ-RP140HA9, PU-RP140HA9

グラフ 記号		バンド Hz								オーバーオール値
		63	125	250	500	1000	2000	4000	8000	dB [A特性]
○	冷房	51.5	53.3	51.2	46.7	44.6	41.8	36.6	30.7	50.0
●	暖房	53.2	55.5	52.6	49.0	46.8	43.5	38.5	32.0	52.0

