

騒音分析成績書

機種：PUZ-ZRP280KA5

グラフ 記号		バンド Hz								オーバーオール値
		63	125	250	500	1000	2000	4000	8000	dB [A特性]
○	冷房	61.7	60.5	59.3	56.5	54.4	49.5	44.6	37.4	59
●	暖房	65.3	64.1	59.7	59.3	58.2	52.4	47.0	41.0	62

