


騒音分析成績表

PUD-P224 (C) M-A (-BS, -BSG)
 PUD-P224 (C) M-A-AC (-BS, -BSG)
 PUD-P224V (C) M-A (-BS, -BSG)
 PUD-P224V (C) M-A-AC (-BS, -BSG)

測定場所: 無響音室
 計器: B&K



63Hz	125Hz	250Hz	500Hz	1000Hz	2000Hz	4000Hz	8000Hz	A特性
66	55	53	55	51	46	41	37	56 (dB)

