



騒音分析成績表

PUHV-P224M-E (-BS, -BSG)

測定場所: 無響音室  
計器: B&K



		63Hz	125Hz	250Hz	500Hz	1000Hz	2000Hz	4000Hz	8000Hz	A特性	
標準	50/60Hz	*62	58	56	52.5	49.5	50	41.5	38	56	(dB)
ナイトモード	50/60Hz	61	54.5	50	46	41.5	39.5	37	38	49	(dB)

