



騒音分析成績表

PUHV-P335M-E (-BS, -BSG)

測定場所: 無響音室
計器: B&K



		63Hz	125Hz	250Hz	500Hz	1000Hz	2000Hz	4000Hz	8000Hz	A特性	
標準	50/60Hz	65	61	58	55	51.5	51	51	45.5	59	(dB)
ナイトモード	50/60Hz	64	55	48.5	46.5	42.5	43	41.5	40	51	(dB)

