



騒音分析成績表

PUHV-P450M-E (-BS, -BSG)

測定場所: 無響音室
計器: B&K



	63Hz	125Hz	250Hz	500Hz	1000Hz	2000Hz	4000Hz	8000Hz	A特性	
標準	50/60Hz	67.5	68.5	60.5	58.5	54.5	50.5	48.5	43	61 (dB)
ナイトモード	50/60Hz	64.5	57.5	54.5	49	48	41.5	39	41	53 (dB)

