



騒音分析成績表

PUHY-P355M-E (-BS, -BSG)

測定場所: 無響音室
計器: B&K



	63Hz	125Hz	250Hz	500Hz	1000Hz	2000Hz	4000Hz	8000Hz	A特性	
標準	50/60Hz	63	64	57.5	55	50.5	50.5	54	50	60 (dB)
ナイトモード	50/60Hz	64	55	48.5	46.5	44.5	45	43.5	42	52 (dB)

