

### 霜取補正

| 室外機外形名                   | 室外吸込空気湿球温度 [°C] |      |      |      |      |      |      |      |      |      |      |
|--------------------------|-----------------|------|------|------|------|------|------|------|------|------|------|
|                          | 6               | 4    | 2    | 1    | 0    | -2   | -4   | -6   | -8   | -10  | -20  |
| PURY-P224CM-E(-BS,-BSG)  | 1.00            | 0.95 | 0.84 | 0.83 | 0.83 | 0.87 | 0.90 | 0.95 | 0.95 | 0.95 | 0.95 |
| PURY-P280CM-E(-BS,-BSG)  | 1.00            | 0.95 | 0.84 | 0.83 | 0.83 | 0.87 | 0.90 | 0.95 | 0.95 | 0.95 | 0.95 |
| PURY-P335CM-E(-BS,-BSG)  | 1.00            | 0.93 | 0.82 | 0.80 | 0.82 | 0.85 | 0.90 | 0.90 | 0.95 | 0.95 | 0.95 |
| PURY-P400CM-E(-BS,-BSG)  | 1.00            | 0.93 | 0.85 | 0.83 | 0.84 | 0.85 | 0.90 | 0.90 | 0.95 | 0.95 | 0.95 |
| PURY-P450CM-E(-BS,-BSG)  | 1.00            | 0.95 | 0.90 | 0.87 | 0.88 | 0.89 | 0.90 | 0.95 | 0.95 | 0.95 | 0.95 |
| PURY-P500SCM-E(-BS,-BSG) | 1.00            | 0.98 | 0.89 | 0.87 | 0.89 | 0.90 | 0.92 | 0.95 | 0.95 | 0.95 | 0.95 |
| PURY-P560SCM-E(-BS,-BSG) | 1.00            | 0.98 | 0.89 | 0.86 | 0.89 | 0.90 | 0.92 | 0.95 | 0.95 | 0.95 | 0.95 |
| PURY-P630SCM-E(-BS,-BSG) | 1.00            | 0.94 | 0.87 | 0.86 | 0.87 | 0.88 | 0.90 | 0.90 | 0.93 | 0.93 | 0.93 |
| PURY-P690SCM-E(-BS,-BSG) | 1.00            | 0.94 | 0.84 | 0.86 | 0.87 | 0.88 | 0.90 | 0.90 | 0.93 | 0.93 | 0.93 |
| PURY-P730SCM-E(-BS,-BSG) | 1.00            | 0.94 | 0.84 | 0.86 | 0.87 | 0.88 | 0.90 | 0.90 | 0.93 | 0.93 | 0.93 |
| PURY-P800SCM-E(-BS,-BSG) | 1.00            | 0.98 | 0.89 | 0.88 | 0.89 | 0.90 | 0.92 | 0.95 | 0.95 | 0.95 | 0.95 |
| PURY-P850SCM-E(-BS,-BSG) | 1.00            | 0.98 | 0.89 | 0.88 | 0.89 | 0.90 | 0.92 | 0.95 | 0.95 | 0.95 | 0.95 |
| PURY-P900SCM-E(-BS,-BSG) | 1.00            | 0.98 | 0.89 | 0.88 | 0.89 | 0.90 | 0.92 | 0.95 | 0.95 | 0.95 | 0.95 |