

## 霜取補正

室外機外形名	室外吸込空気湿球温度 [°C]										
	6	4	2	1	0	-2	-4	-6	-8	-10	-20
PURY-P224CM-E(-BS,-BSG)	1.00	0.95	0.84	0.83	0.83	0.87	0.90	0.95	0.95	0.95	0.95
PURY-P280CM-E(-BS,-BSG)	1.00	0.95	0.84	0.83	0.83	0.87	0.90	0.95	0.95	0.95	0.95
PURY-P335CM-E(-BS,-BSG)	1.00	0.93	0.82	0.80	0.82	0.85	0.90	0.90	0.95	0.95	0.95
PURY-P400CM-E(-BS,-BSG)	1.00	0.93	0.85	0.83	0.84	0.85	0.90	0.90	0.95	0.95	0.95
PURY-P450CM-E(-BS,-BSG)	1.00	0.95	0.90	0.87	0.88	0.89	0.90	0.95	0.95	0.95	0.95
PURY-P500SCM-E(-BS,-BSG)	1.00	0.98	0.89	0.87	0.89	0.90	0.92	0.95	0.95	0.95	0.95
PURY-P560SCM-E(-BS,-BSG)	1.00	0.98	0.89	0.86	0.89	0.90	0.92	0.95	0.95	0.95	0.95
PURY-P630SCM-E(-BS,-BSG)	1.00	0.94	0.87	0.86	0.87	0.88	0.90	0.90	0.93	0.93	0.93
PURY-P690SCM-E(-BS,-BSG)	1.00	0.94	0.84	0.86	0.87	0.88	0.90	0.90	0.93	0.93	0.93
PURY-P730SCM-E(-BS,-BSG)	1.00	0.94	0.84	0.86	0.87	0.88	0.90	0.90	0.93	0.93	0.93
PURY-P800SCM-E(-BS,-BSG)	1.00	0.98	0.89	0.88	0.89	0.90	0.92	0.95	0.95	0.95	0.95
PURY-P850SCM-E(-BS,-BSG)	1.00	0.98	0.89	0.88	0.89	0.90	0.92	0.95	0.95	0.95	0.95
PURY-P900SCM-E(-BS,-BSG)	1.00	0.98	0.89	0.88	0.89	0.90	0.92	0.95	0.95	0.95	0.95