


騒音分析成績表

PUZ-P160IGA(-BS,-BSG)

60Hz

測定場所: 無響音室

計器: B&K



		63Hz	125Hz	250Hz	500Hz	1000Hz	2000Hz	4000Hz	8000Hz	A特性	
60Hz	蓄冷	61.6	44.4	45.0	41.4	37.9	36.4	31.3	33.3	45	(dB)
	冷房/暖房	60.6	49.5	49.7	47.3	43.3	41.9	36.5	31.6	50	(dB)

蓄冷 (60Hz)

冷房/暖房 (60Hz)

