


騒音分析成績表

PFVA-P800(V)DMJ1

測定場所: 無響音室
計器: B & K



63Hz	125Hz	250Hz	500Hz	1000Hz	2000Hz	4000Hz	8000Hz	A特性
71.5	70.5	67.0	61.5	59.5	55.0	50.5	43.0	65.0 (dB)

