


# 騒音分析成績表

PFAV-P1120(V)DMJ1

測定場所: 無響音室  
計器: B & K



63Hz	125Hz	250Hz	500Hz	1000Hz	2000Hz	4000Hz	8000Hz	A特性
73.5	71.5	68.5	64.5	63.5	58.5	54.0	47.0	68 (dB)

