


# 騒音分析成績表

PFAV-P1000(V)DMJ1-F

測定場所: 無響音室  
計器: B & K



63Hz	125Hz	250Hz	500Hz	1000Hz	2000Hz	4000Hz	8000Hz	A特性
63.5	64.0	55.5	52.5	48.0	44.5	39.5	33.0	55 (dB)

