


騒音分析成績表

PFAV-P1250(V)DMJ1-F

測定場所: 無響音室
計器: B & K



63Hz	125Hz	250Hz	500Hz	1000Hz	2000Hz	4000Hz	8000Hz	A特性
64.5	64.5	56.5	54.0	49.5	44.5	39.5	31.5	56 (dB)

