


# 騒音分析成績表

PFAV-P530(V)DMJ1-F

測定場所: 無響音室  
計器: B & K



63Hz	125Hz	250Hz	500Hz	1000Hz	2000Hz	4000Hz	8000Hz	A特性
59.0	54.0	50.5	48.0	44.5	39.5	36.0	26.5	50 (dB)

