


# 騒音分析成績表

PFAV-P1600(V)DMJ1-F

測定場所: 無響音室  
計器: B & K



63Hz	125Hz	250Hz	500Hz	1000Hz	2000Hz	4000Hz	8000Hz	A特性
67.0	65.5	60.0	56.0	49.0	44.0	41.0	34.0	57.5 (dB)

