


騒音分析成績表

PFAV-P335(V)DMJ1-F

測定場所: 無響音室
計器: B & K



63Hz	125Hz	250Hz	500Hz	1000Hz	2000Hz	4000Hz	8000Hz	A特性
56.0	49.5	48.0	44.5	39.5	33.5	28.5	19.0	46 (dB)

