


騒音分析成績表

PFAV-P167(V)DMJ1-F

測定場所: 無響音室
計 器: B & K



63Hz	125Hz	250Hz	500Hz	1000Hz	2000Hz	4000Hz	8000Hz	A特性
48.5	37.0	34.5	26.0	19.0	10.5	10.0	11.0	30 (dB)

