

# 騒音分析成績表(PWL)

MDC-P63LB

測定場所: 無響音室  
計器: B&K

	63Hz	125Hz	250Hz	500Hz	1000Hz	2000Hz	4000Hz	8000Hz	A特性	
50Hz	80.0	80.0	69.0	57.0	59.0	54.0	48.0	44.0	67.0	(dB)
60Hz	77.0	78.0	69.0	56.0	59.0	54.0	48.0	41.0	66.0	(dB)

騒音値はJIS B8616に基づいた値です

