

騒音分析成績表(PWL)

MDK-P63B

測定場所: 無響音室
計器: B&K

| | | 63Hz | 125Hz | 250Hz | 500Hz | 1000Hz | 2000Hz | 4000Hz | 8000Hz | A特性 | |
|------|----|------|-------|-------|-------|--------|--------|--------|--------|------|------|
| 50Hz | Hi | 69.5 | 83.5 | 77.5 | 73.5 | 69.0 | 70.5 | 64.5 | 60.0 | 77.0 | (dB) |
| | Lo | 69.0 | 83.5 | 76.0 | 72.0 | 67.5 | 70.0 | 62.5 | 59.0 | 76.0 | (dB) |
| 60Hz | Hi | 72.0 | 88.0 | 82.0 | 78.0 | 72.5 | 73.5 | 68.0 | 64.0 | 81.0 | (dB) |
| | Lo | 68.0 | 84.0 | 76.0 | 72.5 | 68.5 | 69.0 | 63.0 | 58.5 | 76.0 | (dB) |

騒音値はJIS B8616に基づいた値です

