

騒音分析成績表(PWL)

PCAV-P112DME3

測定場所: 無響音室
計 器: B&K

63Hz	125Hz	250Hz	500Hz	1000Hz	2000Hz	4000Hz	8000Hz	A特性
67.5	69.5	63.0	63.5	62.0	57.5	56.0	45.5	66.5

 (dB)