

騒音分析成績表(PWL)

PCAV-P140DME3

測定場所: 無響音室
計 器: B&K

63Hz	125Hz	250Hz	500Hz	1000Hz	2000Hz	4000Hz	8000Hz	A特性
68.5	70.5	65.5	66.0	64.5	60.0	58.5	48.5	69.0

 (dB)