

騒音分析成績表(PWL)

PFAV-P224DMJ3

50/60Hz

125Hz	250Hz	500Hz	1000Hz	2000Hz	4000Hz	8000Hz	A特性
73.0	70.0	65.5	62.5	56.0	50.5	41.5	68.0

騒音値はJRA4065:2013に基づいた値です

