

騒音分析成績表(PWL)

PFAV-P450DMJ3

50/60Hz

125Hz	250Hz	500Hz	1000Hz	2000Hz	4000Hz	8000Hz	A特性
76.0	75.5	72.5	69.5	65.5	62.5	54.0	75.0

騒音値はJRA4065:2013に基づいた値です

