

騒音分析成績表(PWL)

PFAV-P1400DMJ3

50/60Hz

125Hz	250Hz	500Hz	1000Hz	2000Hz	4000Hz	8000Hz	A特性
85.5	78.0	75.5	69.5	64.0	61.5	55.0	77.0

騒音値はJRA4065:2013に基づいた値です

