

騒音分析成績表(PWL)

PFAV-P1600DMJ3

50/60Hz

125Hz	250Hz	500Hz	1000Hz	2000Hz	4000Hz	8000Hz	A特性
87.0	81.0	77.0	71.5	66.5	63.5	58.0	79.0

騒音値はJRA4065:2013に基づいた値です

