

騒音分析成績表(PWL)

PFAV-P1400DMJ3

—— 50/60Hz

| 125Hz | 250Hz | 500Hz | 1000Hz | 2000Hz | 4000Hz | 8000Hz | A特性 |
|-------|-------|-------|--------|--------|--------|--------|-----------|
| 85.5 | 78.0 | 75.5 | 69.5 | 64.0 | 61.5 | 55.0 | 77.0 (dB) |

騒音値はJRA4065:2013に基づいた値です

