



騒音分析成績表

CMB-P1016HA
CMB-P1016HB



測定場所: 無響音室
計器: B&K


63Hz	125Hz	250Hz	500Hz	1000Hz	2000Hz	4000Hz	8000Hz	A特性 (dB)
35	36.5	41	40	35.5	36	40	41	46



騒音分析成績表

CMB-P1016HA
CMB-P1016HB

測定場所: 無響音室
計器: B&K



電磁弁切換時

63Hz	125Hz	250Hz	500Hz	1000Hz	2000Hz	4000Hz	8000Hz	A特性 (dB)
35.5	37	40.5	39	34.5	35.5	53	43.5	56

